



Question & Answers On The Procurement Of Integrated Fire Safety And Emergency
Equipment Procurement

QUESTION RECEIVED	ANSWERS
General Question	
As bidder how can we be awarded as main bidder per single lot?	Your offer must be the lowest cost technical compliant bid for the specific Lot.
Fees of transportation must include also fees of training?	No, training to operate the equipment is typically provided free of charge by the supplier.
Question related to Lot #1: Supply of Various Fire Extinguishers	
the description indicates ANSI / UL please advise if you accept EN3 Approved Fire extinguishers.	Yes we accept EN3
UL Listings have difference weight standards, (such as 10Lbs = 4.5Kg, 15Lbs = 6.75 kg) which does not match your requirements (for example 6Kg)	Ok, as long as the capacity of the is higher than the requested
Automatic extinguishers do not have UL Listing as they are not classified in the NFPA standard – please advise if you accept CE Certified Automatic Fire Extinguishers.	Yes we accept CE certified automatic extinguisher
Lot#2: Communication and Alert Devices:	
2.6 Fire Alarm 4 Zone and 2.7 Fire Alarm 8 Zone – the fire cable quantity is required to be able to quote properly, with drawings if available.	We are requesting the unit price per meter of the fire cable and the order later on will be based on the number of meters we have in the needed building. In all cases, I can say that the buildings are not of a large scale such as hopitals or... they are LRC centers of maximum 2 to 3 floors
Lot#3: Personal Fire Safety Equipment:	
3.1 Break Glass – is this item a part of the conventional fire alarm requested in Lot#2?	Yes, it is part of the system and it should be as a single item as well, so in case it was defected we can order it aside.
3.3 Fire Blanket – size is required to be able to quote properly (1m x 1m, 1.2m x 1.2m, 1.8m x 1.8m)	1.2m*1.8m, this is the standard size that we used to order.
3.4 Fire Face Mask – is the mentioned Model No. CH-M002 is the only model acceptable? If yes, kindly advise in return the brand.	No specific brand but it must be of a good quality/for firefighting.
3.6 Safety Gloves – in the description, it is mentioned “Neck Protector: Two layer, outer layer is aramid fiber, inner layer is fire retardant cotton” what do you mean by it?	Gloves made from cotton and leather and 2 layers
3.11 10mm Climbing Rope – how many meters is required.	Price should be per 1 meter
3.12 Chopper Axe – please advise if you accept full steel chopper axe with rubber handle.	Yes
Lot#6: Firefighting Tools and Equipment:	
6.10 Fire Swatter Flap and 6.24 Fire Beater – the fire swatter is a fire beater. Please advise the difference between these two items, as there is no additional information for item 6.24.	Same yes